



ETC Engineers & Architects, Inc.

ENGINEERS ■ ARCHITECTS ■ PLANNERS

■ 1510 SOUTH BROADWAY, LITTLE ROCK, AR 72202 ■ PHONE 501-375-1786 ■ FAX 501-375-1277 ■

ADDENDUM NO.3

DATE: April, 3, 2017
PROJECT: Larry S. Bryant Health & Wellness Center Expansion / Aquatic Center
Forrest City, AR
ETC Project No.: 133901CFC

TO ALL PROSPECTIVE BIDDERS:

This Addendum forms a part of the Contract Documents and modifies or interprets the Project Manual and drawings as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

GENERAL:

1. **Swimming Pool Lights Clarification:** The swimming pool lights and the related junction boxes are to be supplied by the swimming pool contractor. The electrical contractor will run conduits; install the junction boxes and wiring.

Architectural Drawings

2. **Sheet A1.0:** Revised Note 3 to **add a HSS10x6x5/16"** structural steel beam at curtainwall
3. **Sheet A3.1:** Revised Building Section 1, Glazed Units **C and C.1** to correspond to the Elevations and Window Types
4. **Sheet A3.1:** Revised Keynote 8.3 to indicate the sliding glass doors to be **CRL – U.S. Aluminum 3000 Thermal Sliding Glass Doors** in lieu of Kawneer AA3900
5. **Sheet A5.10:** Revised Wall Sections to **add a HSS10x6x5/16"** steel beam at the curtainwall/new roof. Revised note to indicate existing curtainwall system in lieu of storefront system

Project Manual

1. Revised Specification Section 07450 - Thermoplastic Roofing to indicate acceptable Product Alternatives.
2. Added Specification Section 08330 – Rolling Aluminum Service Door
3. Revised Specification Section 08800 – Glazing to clarify the composition of the 1" insulated glazing units

BUILDING A BETTER WORLD

■ e-mail: etc@etcengineersinc.com ■





ETC Engineers & Architects, Inc.

ENGINEERS ■ ARCHITECTS ■ PLANNERS

■ 1510 SOUTH BROADWAY, LITTLE ROCK, AR 72202 ■ PHONE 501-375-1786 ■ FAX 501-375-1277 ■

4. **Revised Specification Section 08321 – Sliding Glass Doors to indicate CRL – U.S. Aluminum 3000 Thermal Sliding Glass Doors as the basis of design in lieu of Kawneer AA3900**

End of Addendum 3

BUILDING A BETTER WORLD

■ e-mail: etc@etcengineersinc.com ■

